

Programming the Lutron myRoom Solution for Title 24 Part 6 Compliance

This application note is intended to address questions about the 2019 edition of the California Title 24 Part 6 Building Energy Standard and how it applies to the Lutron myRoom system, specifically on the programming of guest room minimum and maximum setpoints and temperature setbacks when the hotel guest room is in an unoccupied state.

Requirements

The applicable sections of the standard are the following:

- Section 120.2(c)1B - Have setpoint stops, which are accessible only to authorized personnel, such that guest room occupants cannot adjust the setpoint more than ± 5 °F (± 3 °C)
- Section 120.2(e)4 - Hotel and motel guest rooms shall have captive card key controls, occupancy sensing controls, or automatic controls such that, no longer than 30 minutes after the guest room has been vacated, setpoints are setup at least +5 °F (+3 °C) in cooling mode and set-down at least -5 °F (-3 °C) in heating mode.

Programming Requirements

Programming a Lutron myRoom system to be compliant with these provisions involves the following steps:

1. The temperature range between the minimum and maximum guest selectable setpoints for the Palladiom thermostat must be ± 5 °F (± 3 °C).
 - a. For example, for a hotel default setpoint of 70 °F (21 °C), the minimum allowable setpoint should be 65 °F (18 °C), and the maximum allowable setpoint should be 75 °F (24 °C).
2. The timeout for the Guest Presence Detection algorithm should be set to no more than 30 minutes.
3. The drift settings during an unoccupied state should be set to at least ± 5 °F (± 3 °C).

Conclusion

For more information regarding Lutron myRoom solutions, visit www.lutron.com. If you require assistance on a project, contact your local Lutron representative. For technical questions regarding compatibility, contact the System Sales Engineering team at systemsalesengineers@lutron.com

To download the full 2019 edition of the California Title 24 Part 6 Building Energy Standard, please visit <https://www.energy.ca.gov/programs-and-topics/programs/building-energy-efficiency-standards/2019-building-energy-efficiency>

Lutron, myRoom, and Palladiom are trademarks or registered trademarks of Lutron Electronics Co., Inc. in the US and/or other countries.

Lutron Contact Numbers

WORLD HEADQUARTERS

USA
Lutron Electronics Co., Inc.
7200 Suter Road
Coopersburg, PA 18036-1299
TEL: +1.610.282.3800
FAX: +1.610.282.1243
support@lutron.com
www.lutron.com/support

**North & South America
Customer Assistance**
USA, Canada, Caribbean:
1.844.LUTRON1 (1.844.588.7661)
Mexico:
+1.888.235.2910
Central/South America:
+1.610.282.6701

UK AND EUROPE:

Lutron EA Limited
125 Finsbury Pavement
4th floor, London EC2A 1NQ
United Kingdom
TEL: +44.(0)20.7702.0657
FAX: +44.(0)20.7480.6899
FREEPHONE (UK): 0800.282.107
Technical Support: +44.(0)20.7680.4481
lutronlondon@lutron.com

ASIA:

Lutron GL Ltd.
390 Havelock Road
#07-04 King's Centre
Singapore 169662
TEL: +65.6220.4666
FAX: +65.6220.4333
Technical Support: 800.120.4491
lutronsea@lutron.com

Asia Technical Hotlines

Northern China: 10.800.712.1536
Southern China: 10.800.120.1536
Hong Kong: 800.901.849
Indonesia: 001.803.011.3994
Japan: +81.3.5575.8411
Macau: 0800.401
Taiwan: 00.801.137.737
Thailand: 001.800.120.665853
Other Countries: +65.6220.4666