
# **Multi-Stall Restroom | New Construction**

ASHRAE 90.1-2013





	wiring
	Low-voltage wiring
₹.	Clear Connect RF Communication

Symbol	Model Number	Description	Qty
	RMJS-8T-DV-B	PowPak dimming module with 0-10V	1
	LRF2-OCR2B-P-WH	Radio Powr Savr wireless ceiling-mount occupancy sensor	2
	PJ2-3BRL-GWH-L01	Pico wireless 3-button with raise/lower control	1
	PICO-WBX-ADAPT	Pico wallbox adapter	1

# **Control Functionality**

### **Occupant Enters:**

All lights automatically turn on to maximum light level. Maximum light level is set to 80%.

### When Occupied:

Manual: Occupant uses wall dimmer to set desired light levels for all lights.

### **Occupant Exits:**

All lights automatically turn off 15 minutes after all occupants exit.

Add a Vive wireless hub to enable simple setup and re-zoning, system monitoring, timeclock functionality, and advanced integration.

Code Notes: Add a daylight sensor for restrooms with daylight zones.

Want to add a Vive wireless hub for more features? Go to lutron.com/vive for complete compatibility and design details. This solution requires 0-10V enabled ballasts and drivers by others.