Room Thermostat

369861w 1 09.05.24

myRoom Palladiom QS Thermostat

The myRoom Palladiom QS thermostat is a user interface to an HVAC equipment controller. The large backlit LCD display is easy to see and use, while a built-in Passive Infrared (PIR) sensor detects occupants moving within an area and works with other system components to determine when the space is occupied.

Model Number

MWP-T-OHW-XXX*-A — myRoom Palladiom QS thermostat

Features

- Aesthetically coordinates with Palladiom keypads.
- Compatible with the following HVAC system interfaces:
 - Lutron Fan Coil Unit (FCU) controller
 (see spec 3691082 at www.lutron.com)
 ^o 2-pipe or 4-pipe hydronic systems
 - 3-speed or 0–10 V== variable fan speed control
 - On/Off or 0–10 V=== modulating valve control
 - Specific VRV/VRF systems via BACnet_® (see page 4)
 - Specific VRV/VRF systems via wired third-party HVAC controller interface (see page 6)
- Backlit screen and buttons are easy to operate in a dark room. The backlit screen and the buttons will dim to a pre-selected level when not in use.
- Ability to lock out local button control via myRoom Plus and myRoom XC system configuration.**
- Built-in vandal-resistant PIR motion sensor with Lutron exclusive XCT detection technology.
- Built-in room temperature sensor.
- Programmable active backlight timeout.

**		°C .5	
\bigcirc	°C °F	^	
È		\sim	

- The FCU controller supports an optional wired remote temperature sensor to allow for flexibility regarding thermostat installation location. When installed, the wired remote temperature sensor is used instead of the internal thermostat sensor.
- IEC PELV/SELV/NEC_® Class 2 control.
- myRoom guestroom control solutions save energy by automatically adjusting the room temperature setpoint based on guest occupancy.
- myRoom Plus and myRoom XC can save energy based on room sold/unsold information from the hotel property management system.

Dogo

* "XXX" in the model number will be 2 or 3 letters that represent color/finish code. See Colors and Finishes.

** Available with myRoom Palladiom thermostat version 3.11 or newer.

SPECIFICATION SUBMITTAL		Fage
Job Name:	Model Numbers:	
Job Number:		

Room Thermostat

Specifications

Regulatory Approvals

- Lutron Quality Systems registered to ISO 9001:2015
- Compliant with IEC 60730
- cULus Listed
- NOM Certified
- RoHS Compliant
- FCC Part 15 Compliant
- ICES-003 Compliant
- CE Marked
- UKCA Marked

Power Input

- IEC PELV/SELV/NEC_® Class 2
- Operating voltage: 24-36 V== 60 mA

System Communication and Capacity

- IEC PELV/SELV/NEC_® Class 2 wiring connects Palladiom QS thermostats to other devices on the QS Link.
- A Palladiom QS thermostat consumes 3 power draw units (PDU) on the QS link. For complete information, see "Power Draw Units on the QS Link" (P/N 369405) at www.lutron.com

Terminals

Each terminal accepts up to two 18 AWG (1.0 mm²) wires or one 22 AWG to 12 AWG (0.5 mm² to 2.5 mm²) solid or stranded wires.

Environment

- Ambient operating temperature: 32 °F to 104 °F (0 °C to 40 °C)
- Maximum 90% non-condensing relative humidity
- Indoor use only
- IP20 Rating

Compatibility

• Palladiom QS thermostats are compatible with myRoom XC, myRoom Plus, and myRoom Prime systems.

Room Temperature Sensor

- Measuring range: 32 °F to 99 °F (0 °C to 37 °C)
- Accuracy
 - At 70 °F: < +/– 1 °F
 - − At 25 °C: < +/− 0.5 °C
- 5% to 90% non-condensing, relative humidity

Relative Humidity Sensor

- Accuracy
 - Between 0% and 80%: < +/- 3%
 - Between 80% and 100%: < +/- 5%

Temperature Setpoint and Display

- The Palladiom QS thermostat is adjustable in 1 °F (0.5 °C) increments.
- The Palladiom QS thermostat displays room temperature in 1 °F (0.5 °C) increments.
- Toggle between Fahrenheit and Celsius temperature units with a button press or Lutron Integration Protocol command.

Warranty

• Limited Warranty: www.lutron.com/warranty or call 1.844.LUTRON1 for a printed copy

Continued on the next page...

Dago

LUTRON SPECIFICATION SUBMITTAL

SFLUITOATIO	N SOBMITIAL	Faye
Job Name:	Model Numbers:	
Job Number		

369861w 3 09.05.24

Wallbox

- Requires a 2.75 in x 2.75 in (70 mm x 70 mm) metal conduit box with a minimum depth of 1.38 in (35 mm).
 - Single wallbox: Lutron model number EBB-1-SQ
 - Pack of 15 wallboxes: Lutron model number EBB-15-SQ
- If the wallbox has top or bottom mounting tabs, bend them back before installing the adapter.
- If running conduit to the wallbox, use a low-profile conduit connector with a maximum height of 0.125 in (3 mm).

Mounting

- Mount on a clean, dry, interior wall.
- Mount approximately 4 ft to 5 ft (1.2 m to 1.5 m) above the floor. Follow all local and national codes.
- Mount on a wall without pipes, chimneys, or ducts.
- Mount on a wall with good visibility and control access.
- Do not mount on an exterior wall, close to a window, next to a door, or areas with drafts.
- Do not mount in direct airflow from supply and return registers/grilles.
- Do not expose to water (e.g., drips or splashes) or mount in a damp area.
- Do not mount within 4 ft (1.2 m) of heating sources (e.g., direct sunlight, light bulbs, etc.).
- Do not mount in areas with poor circulation (e.g., niches, alcoves, behind curtains, or behind doors).
- Do not mount within 0.75 in (19 mm) of Palladiom keypads, receptacles, or accessories.

LUTRON SPECIFICATION SUBMITTAL

Model Numbers:

Job Name:

Job Number:

_		
D	20	10
E .	au	10

Room Thermostat

369861w 4 09 05 24

HVAC via BACnet_® System Diagram

The myRoom Palladiom thermostat is able to interface with HVAC systems via BACnet® in a myRoom XC or myRoom Plus system.*



There are several requirements for interfacing to a HVAC system via BACnet® that must be met in order to achieve optimal performance. Lutron strongly recommends reviewing these requirements with the HVAC manufacturer, the HVAC contractor, the BACnet_® integrator, the mechanical, electrical, plumbing (MEP) engineer, and the Lutron project manager and/or field service.

- 1. HVAC system performance (e.g., delays, changeover temperature differential) is dictated by the HVAC system. The Palladiom QS thermostat provides operating mode, fan mode, and setpoint to the system.
- 2. The current zone temperature must be provided via BACnet_® by the HVAC system to the Lutron system in order to have it displayed on the Palladiom QS thermostat and in myRoom dashboard software. The local Palladiom temperature sensor is disabled. If the thermostat does not receive a temperature via BACnet_® within 5 minutes of being powered, an E4 error will be displayed.
- 3. Call status (actively heating/cooling) must be provided via BACnet_® by the HVAC system in order for:
 - a. The Palladiom thermostat to indicate the status on the display.
 - b. myRoom dashboard to be able to provide HVAC status, HVAC energy reporting, and HVAC data logging.
- 4. Fan status must be provided via BACnet[®] by the HVAC system in order for myRoom dashboard to provide HVAC energy reporting and HVAC data logging.
- 5. The Palladiom QS thermostat supports 1 °F/0.5 °C resolution temperature changes independent of the resolution supported by the HVAC equipment connected via BACnet®.

* Available with myRoom Palladiom thermostat version 3.11 or newer.

Continued on the next page...

LUTRON SPECIFICATIO	N SUBMITTAL	Page
Job Name:	Model Numbers:	
Job Number:		

HVAC via BACnet_® System Diagram (continued)

- 6. The myRoom system supports OFF and AUTO operating modes. Other operating modes are NOT supported (e.g., heat, cool).
- 7. The myRoom system supports either a single setpoint with positive and negative drifts or a heat and cool set-point. When drifts equal 0, single setpoint, heat set-point, and cool set-point will be the same. If the HVAC system does not accept identical heat and cool set-points then drifts must be set in the myRoom system such that the heat and cool set-points are spaced greater than the minimum required by the HVAC system.
- 8. The myRoom system supports LOW, MEDIUM, HIGH, and AUTO fan modes.

- 9. When the operating mode is OFF, the fan mode will always be OFF. When the operating mode is AUTO, the fan mode can never be OFF.
- 10. The temperature scale (°C/°F) displayed on the Palladiom QS thermostat can be changed locally at the thermostat. It cannot be changed via BACnet®.
- 11. If the BACnet® system loses communication with the Palladiom QS thermostat, the HVAC system must have its own method to maintain temperature.
- 12. myRoom dashboard will not show the HVAC system alerts and alarms when the HVAC system is connected via BACnet_®.

For a complete list of available BACnet_® objects in myRoom Plus, see BACnet_® PIC Statement for myRoom Virtual Devices (P/N 3691087) at www.lutron.com

For a complete list of available BACnet_® objects in myRoom XC, see BACnet_® PIC Statement for myRoom XC (P/N 369127) at www.lutron.com

LUTRON SPECIFICATION SUBMITTAL

LUTRON SPECIFICATION SUBMITTAL		Page
Job Name:	Model Numbers:	
Job Number:		

myRoom

369861w 6 09 05 24

VRV/VRF via wired third-party HVAC controller System Diagram



- 1. Indoor unit must support auto, heat, cool, and fan mode.
- 2. The Palladiom thermostat will not display the HVAC system error codes or call for heat or cool. Energy monitoring in myRoom dashboard is not available while interfacing with thirdparty controllers.
- 3. The Palladiom thermostat will overwrite changes made from outside the Lutron system so that the HVAC system continues to operate based on the Palladiom thermostat's programmed information.
- 4. The VRV/VRF manufacturer's thermostat must be removed from "Manufacturer Specific Communication Link". Leaving it connected can cause issues in communication between wired HVAC controller and VRV/VRF systems.
- 5. The LG-PDRYCB500 and Procon A1M controllers are not sold by Lutron. Contact VRV/VRF system manufacturer for ordering and
- confirming compatibility.
- 6. CoolPlug is sold by CoolAutomation. Contact CoolAutomation for ordering and confirming compatibility.
- The AirZone Aidoo is sold by AirZone. Contact AirZone for ordering and confirming compatibility.
 All third-party controllers are designed for one-to-one controls. Multiple VRV/VRF systems must not be connected to a single third-party controller.

Model Numbers:

- Multiple third-party controllers must not be connected to a single myRoom Palladiom thermostat.
- Inbuilt humidity sensor of the myRoom Palladiom thermostat is not available when interfacing with third-party controllers. Inbuilt temperature sensor of the myRoom Palladiom thermostat is available when interfacing with third-party controllers. Requires myRoom Palladiom thermostat firmware v5.018 or later.
- 10.If VRV/VRF system supports only cooling or only heating, verify the available op-modes are correctly configured in Q-Design for myRoom Plus and myRoom Prime or in Lutron Designer software for myRoom XC. This cannot be programmed to change automatically based on sensors.

LUTRON SPECIFICATION SUBMITTAL

Page

Job	Number:	

Job Name:

Room Thermostat

369861w 7 09.05.24





LUTRON SPECIFICATION SUBMITTAL

Page Job Name: Model Numbers: Job Number:

Dimensions

Measurements shown as: in (mm)

Front View



Rear View



Side View



Wallbox (EBB-1-SQ)



SPECIFICATION SUBMITTAL Ś

	UTRON SPECIFICATION SUBMITTAL		Page
Job Name:		Model Numbers:	
Job Number:			

(3)

PIR Sensor Placement and Operation

- The ability of the PIR sensor to detect motion requires line-of-sight of room occupants. The PIR sensor must have an unobstructed view of the room.
- Hot objects, moving air currents, and automated shades can affect the performance of the PIR sensor. For best performance, the PIR sensor should be mounted at least 4 ft (1.2 m) away from HVAC vents and light bulbs.
- The performance of the PIR sensor depends on a temperature differential between the ambient room temperature and that of room occupants. Warmer rooms may reduce the ability of the PIR sensor to detect occupants.
- For use as part of the guest presence detection feature to control lights and thermostat based on the occupancy state. PIR sensor is not intended to control lights, thermostat, or shades without using the myRoom Guest Controls solution.
- PIR sensor is not intended to control lights, thermostat, or shades without using guest presence detection.
- 180° sensor field-of-view
- Sensitivity options:
 - High sensitivity (default)
 - Low sensitivity
- Coverage
 - 30 ft x 30 ft (9 m x 9 m)
 - 900 ft² (81 m²)
- Vandal resistant with reinforced metal bar behind lens

LUTRON SPECIFICATION SUBMITTAL

Page

		1 498
Job Name:	Model Numbers:	
Job Number:		

369861w 10 09.05.24









(for reference only)



LUTRON SPECIFICATION SUBMITTAL		Page
Job Name:	Model Numbers:	
Job Number:		

QS Link Wiring

- Use IEC PELV/SELV/NEC_® Class 2 (24-36 V==) wiring to connect the thermostat to the QS link for power and communication.
- Connect two 22 AWG (0.5 mm²) shielded, twisted pair wires to terminals 3 and 4. Shielding (drain) of the twisted pair wires must be connected together as shown, but do not connect the shielding to earth/ground or the thermostat and do not allow it to contact the grounded wallbox.
- Connect the appropriate size wires to terminals 1 and 2 for power, according to your link length (see table below).
- Connect Drain/Shield as shown. Do not connect to Ground (Earth) or the thermostat. Connect the bare drain wires and cut off the outside shield.

Note: Use appropriate wire connecting devices as specified by local codes.



Link Wiring 500 ft to 2000 ft (153 m to 610 m)



QS Link Wire Sizes (check compatibility in your area)

QS Link Wiring Length	Wire Gauge	Lutron Cable Part Number
L and then 500 ft (152 m)	Power (terminals 1 and 2) 1 pair 18 AWG (1.0 mm ²)	GRX-CBL-346S (non-plenum)
Less than 500 ft (155 ff)	Data (terminals 3 and 4) 1 twisted, shielded pair 22 AWG (0.5 mm ²)	GRX-PCBL-346S (plenum)
500 ft to 2000 ft	Power (terminals 1 and 2) 1 pair 12 AWG (4.0 mm ²)	GRX-CBL-46L (non-plenum)
(153 m to 610 m)	Data (terminals 3 and 4) 1 twisted, shielded pair 22 AWG (0.5 mm ²)	GRX-PCBL-46L (plenum)

COLEICATION CUDMITTAI

	SPECIFICATION	I SUBMITIAL	Page
Job Name:		Model Numbers:	
Job Number:			

Fan Coil Unit Controller Wiring

• See "Fan Coil Unit Controller" spec submittal (P/N 369962) at www.lutron.com for more information.



Fan Coil Unit Controller Wiring	Wire Gauge	Lutron Cable Part Number
Up to 500 ft (152 m)	Common: 18 AWG or 22 AWG	GRX-CBL-346S
	$(1.0 \text{ mm}^2 \text{ or } 0.5 \text{ mm}^2)$	(non-plenum)
	MUX, MUX: 1 twisted, shielded pair	GRX-PCBL-346S (plenum)
	18 AWG or 22 AWG (1.0 mm ² or 0.5 mm ²)	

User Interface



¹ Turns on when any button is pressed. Turns off after 10 seconds of inactivity.

² Room temperature and "OFF" are shown when system is off.

³ Display shows the current room temperature. First Raise/Lower button press changes the display to show the room setpoint. Further Raise/Lower button presses adjust the room setpoint.

⁴ Display always shows the room setpoint. The first Raise/Lower button press activates the LCD backlight. Additional Raise/Lower button presses adjust the room setpoint. NOTE: Button backlighting adjustable through system software.

CLUTRON SPECIFICATION SUBMITTAL

LUTRON SPECIFICATION SUBMITTAL		Page
Job Name:	Model Numbers:	
Job Number:		

369861w 13 09.05.24

Colors and Finishes Architectural Matte Finishes

Thermostat



Architectural Metal Finishes

Thermostat



Signature Metal Finishes

Thermostat



Glass Finish

Thermostat



- Due to printing limitations, colors and finishes shown cannot be guaranteed to perfectly match actual product colors.
- PD-CK-1 (Architectural finishes) and SM-CK-1 (Signature Metal finishes) chip sample sets are available to represent these colors and finishes. Chips should not be used for exact matching of the color or finish.**

Antique Brass is a handcrafted finish that is created using a manual relief process. This artisanal process can result in variations in luster, hue and appearance. ** Contact Lutron prior to using any samples for matching of non-Lutron product.

The Lutron logo, Lutron, myRoom, Palladiom, and XCT are trademarks or registered trademarks of Lutron Electronics Co., Inc., in the U.S. and other countries. All other product names, logos, and brands are property of their respective owners.

LUTRON SPECIFICATION	N SUBMITTAL	Page
Job Name:	Model Numbers:	
Job Number:		